

STRUCTURAL SOUNDNESS CERTIFICATE

STATEMENT ACCOMPANYING FORM - A

- 1) Door number of the building : Nil
- 2) Location : **Jayam Vidhyalaya School,**
(Street number, Ward number, (Run by Sri Venkateshwara Trust),
Name of place, i.e. Corporation / S.F. No. 99/3C1B, 99/3C2B,
Municipality / Panchayat Union / 100/1A & 100/1B1,
Township / Contonment) Nambippatti Village,
Chinnankuppam Panchayat,
Pappireddipatti Taluk,
Dharmapuri District.
- 3) Year of construction : 2025
- 4) Approximate cost of construction : Rs. 4,70,00,000/-
as per current rates
- 5) Purpose for which the building is : School purpose
being used or proposed to be used (CBSE School)
- 6) Purpose for which the building : New construction
has hitherto been used
- 7) Details of construction of the building
(Particulars of the foundations soil,
Specification of various parts under)
- a) Foundation : RCC column & footing
- b) Basement : RCC column & plinth beam
- c) Super structure : Brick walls in cement mortar
- d) Floor and roof are to be given :
- | | <u>Floor</u> | <u>Roof</u> | <u>Area</u> |
|---|--------------|-------------|---------------|
| : | Ground floor | RCC roof | 12054.93 sqft |
| : | First floor | RCC roof | 12054.93 sqft |
| : | Second floor | RCC roof | 12054.93 sqft |




- 8) Period for which licence is required : 01.05.2025 to 30.04.2028.
- 9) No. of persons to be accommodated : 1000 Students only.
(One thousand students only)

Date : 25.04.2025

- Encl :- 1. Declaration (Page No.7)
2. Dharmapuri Collector Panel order

Proceedings of Dharmapuri Dist
Collector P.D. No. 62891/2000

Signature of the Panel Engineer



Certified that no addition or alteration has been made to the existing building or portion of a building for which this application has been made. I undertake to obtain a fresh licence in case any addition or alteration is made to the existing building or portion of building. I also undertake to obtain a fresh licence if the purpose for which the licence was granted for the use of the building or portion of building originally is changed or altered subsequently.

This is further to certify that no thatched buildings / inflammable roof buildings are used within this premises for the purpose noted in the statement. Any thatched building constructed / used after issue of this certificate, I would be held responsible for fire accident / mishap that may occur later and I am aware of that it is a punishable crime. Also other buildings of any types within this premises which were not opted / covered for the purpose which the licence was granted would be brought under the risk of my own.

The revenue details (Survey numbers, area & boundaries etc.,) and building details (Founadtion, year of construction etc.,) metioned in this certificate were provided by me only.

Date : 25.04.2025

Signature of the owner of the building

CORRESPONDENT
Jayam Vidhyalaya School
Nambipatti-636 903,
Mambur-Tk. Dharmapuri-Dt.

FORM - B

(Form of Certificate of Structural Soundness under sub-section(4) of section 4 of the Tamilnadu Public Buildings (Licensing) Act 1965 (Tamil Nadu Act 13 of 1965) referred to in rule 4 of the Tamilnadu Public Buildings (Licensing) Rules 1966).

I certify that I have inspected the building mentioned in the statement and furnish below its salient technical features.

1) Foundation :

- | | | |
|---|---|-----------------------|
| i) Depth below ground level | : | 2.00 m |
| ii) Nature of soil met with at foundation level | : | Hard Gravel |
| iii) Pressure at foundation | : | 120 kN/m ² |
| iv) Probable safe bearing capacity of the strata met with at foundation | : | 300 kN/m ² |

2) Super structure :

- | | | | |
|--|---|-------------------------------------|-----------------------------------|
| i) Maximum stress in the most critical section of masonry and concrete | : | Masonry - 0.20 N/mm ² | Concrete - 5.00 N/mm ² |
| ii) Nature of Masonry & Concrete and its safe permissible stress | : | Brick work - 0.35 N/mm ² | Concrete - 9.00 N/mm ² |

The structural soundness of the building has been verified by me with reference to ISI loading standards 875 (latest version) and other relevant Indian Standard Code of practice and I declare that the building is structurally sound to be used as a public building for the purpose noted in the statement. A licence may be granted for the period from **01.05.2025 to 30.04.2028.**

Date : 25.04.2025

Proceedings of Dharmapuri Dist
Collector R.Dis. 62881/2000.

Signature of the Panel Engineer

Dr. P.N. RAMESH BABHU,
B.E., M.Tech., M.Sc(RV), MIE, FIV, FIGV, C.Eng(I), AMITA, MCI,
Chartered Engineer (M-11988-688)
Govt. Approved Valuer (P-1410)
Approved Valuer for Immovable Properties (P-8886)
Regd. Valuer for Wealth Tax (C-4442-99) & RBI (14882/21)
Regd. Engineer Class 1A (TN Public Buildings Act)
Panel Valuer for Banks, RBF, IOCL, HPCL & NHA
Mobile: 94434 42002. Email: nrassociaates@gmail.com



STATEMENT TO ACCOMPANY
THE CERTIFICATE OF STRUCTURAL SOUNDNESS

1)	Location of the building (Door No, street name and name of the place)	Jayam Vidhyalaya School, (Run by Sri Venkateshwara Trust), S.F. No. 99/3C1B, 99/3C2B, 100/1A & 100/1B1, Nambippatti Village, Chinnankuppam Panchayat, Pappireddipatti Taluk, Dharmapuri District.
2)	Age of the building	New building
3)	The Value of the building as per current rate	Rs. 4,70,00,000/-
4)	Number of Storeys	G + 2
5)	Short description of structures (Steel/RCC framed/Loadbearing)	RCC framed structure
6)	Purpose for which the building is certified for use	School purpose (CBSE School)
7)	The period for which the building will be structurally sound	01.05.2025 to 30.04.2028.
8)	No. of persons to be accommodated	1000 Students only. (One thousand students only)
9)	Remarks	Nil

Date : 25.04.2025

Signature of the Panel Engineer

Proceedings of Dharmapuri Dist
Collector R.Dis. 62891 / 2000.

(Handwritten Signature)

Er. P.N.RAMESH BAABHU,
B.E., M.Tech, M.Sc(RV), MIE, FIV, FIGV.C. Eng(I), MHTA, MIC,
Chartered Engineer (M-11995-6/99)
Govt. Approved Valuer (F-1410)
Approved Valuer for Immovable Properties (F-5036)
Regd. Valuer for Wealth Tax (C-442-99) & RBI (1488221)
Regd. Engineer Class 1A (TN Public Buildings Act)
Panel Valuer for Banks, NDFI, IOCL, HPCL & NHAI
MobNo:94434 42002, Email: rameshbaabhu@gmail.com



FORM - C

(Form of Opinion under sub-section (1) of section 5 of Tamilnadu Public Buildings (Licensing) Act 1965 (Chennai Act 13 of 1965) referred to in Rule 5 of the Tamilnadu Public Buildings (Licensing) Rules 1966).

I certify that I have inspected the building mentioned in the statement and furnish below its salient technical features.

1) Foundation :

- | | | |
|---|---|-----------------------|
| i) Depth below ground level | : | 2.00 m |
| ii) Nature of soil met with at foundation level | : | Hard Gravel |
| iii) Pressure at foundation | : | 120 kN/m ² |
| iv) Probable safe bearing capacity of the strata met with at foundation | : | 300 kN/m ² |

2) Super structure :

- | | | | |
|--|---|--------------|------------------------|
| i) Maximum stress in the most critical section of masonry and concrete | : | Masonry - | 0.20 N/mm ² |
| | | Concrete - | 5.00 N/mm ² |
| ii) Nature of Masonry & Concrete and its safe permissible stress | : | Brick work - | 0.35 N/mm ² |
| | | Concrete - | 9.00 N/mm ² |

The structural soundness of the building has been verified by me with reference to ISI loading standards 875 (latest version) and other relevant Indian Standard Code of practice and I declare that the building is structurally sound to be used as a public building for the purpose noted in the statement. A licence may be granted for the period from **01.05.2025 to 30.04.2028.**

Date : 25.04.2025

Proceedings of Dharmapuri Dist
Collector R. Dis. 62091/2000.

Signature of the Panel Engineer

Er. P.N.RAMESH BABHU,
B.E., M.Tech., M.Sc.(RV), MIE, FIV, FIGV, C.Eng(I), MIFA, MCI,
Chartered Engineer (M-11998-688)
Govt. Approved Valuer (F-1410)
Approved Valuer for Immovable Properties (F-5000)
Regd. Valuer for Wealth Tax (C-0442-99) & IBSI (14032/21)
Regd. Engineer Class 1A (TN Public Buildings Act)
Panel Valuer for Banks, NSFI, IOCL, HPCL & NHAI
Mobile: 94434 42002. Email: rneasociates@gmail.com

STATEMENT TO ACCOMPANY
THE OPINION ON STRUCTURAL SOUNDNESS

1)	Location of the building (Door No, street name and name of the place)	Jayam Vidhyalaya School, (Run by Sri Venkateshwara Trust), S.F. No. 99/3C1B, 99/3C2B, 100/1A & 100/1B1, Nambippatti Village, Chinnankuppam Panchayat, Pappireddipatti Taluk, Dharmapuri District.
2)	Age of the building	New building
3)	The Value of the building as per current rate	Rs. 4,70,00,000/-
4)	Number of Storeys	G + 2
5)	Short description of structures (Steel/RCC framed/Loadbearing)	RCC framed structure
6)	Purpose for which the building is certified for use	School purpose (CBSE School)
7)	The period for which the building will be structurally sound	01.05.2025 to 30.04.2028.
8)	No. of persons to be accommodated	1000 Students only. (One thousand students only)
9)	Remarks	Nil

Date : 25.04.2025

Signature of the Panel Engineer

Proceedings of Dharmapuri Dist
Collector R.Dis. 62891 / 2000.


Er. P.N. RAMESH BABHU,
B.E., M.Tech., M.Sc(RV), MIE, FIV, FIGV, C Eng(I), MITA 1st
Chartered Engineer (M-11995-6/99)
Govt. Approved Valuer (P-1410)
Approved Valuer for Immovable Properties (P-5036)
Regd. Valuer for Wealth Tax (C-4442-99) & RBI (14832/21)
Regd. Engineer Class 1A (TN Public Buildings Act)
Panel Valuer for Banks, NBFI, IOCL, HPCL & NHAI
Mobile: 94494 42002, Email: rrasocdotes@gmail.com

DECLARATION

I, **Er. P.N. Ramesh Baabhu** son of Mr. P.M. Natarajan residing at D.No. 1A, TAMS Colony II cross, Old Railwayline road, Dharmapuri - 636701, Dharmapuri District do hereby declare that I possess the qualification and experience specified in the Table Rule 11 of the Tamil Nadu Public Buildings (Licensing) Rules 1966, for issuing the Certificate of Structural Soundness of the building covered by the certificate.

I am an **APPROVED & REGISTERED ENGINEER** with the **Collector of Dharmapuri District** under Tamil Nadu Public Buildings (Licensing) Act 1965 & Rules 1966 to issue the Structural Soundness Certificate to public buildings.


Signature of the Panel Engineer

- | | | | |
|----|---------------------------|---|---|
| 1) | Name in Block letters | : | P.N. RAMESH BAABHU |
| 2) | Engineering Qualification | : | BE, M.Tech, M.Sc(Val), MIE, FIV, CEng(I), MIITA, MICI, MASME, |
| 3) | Experience | : | * 36 years as a Chartered Civil Engineer.
* Regd. Engineer Class-1A category by BOE.
* Panel Engineer with the Collector of Dharmapuri District (R.Dis 62891/2000) |

Disclaimer :

- 1) This certificate does not covers Legal aspects (Ownership, Survey numbers, boundaries & Area of the site) and issued without Prejudice.
- 2) This certificate does not covers and out-of-scope for any natural disasters like earthquake, cyclone, fire & anyother impacts which affects the stability of the buildings and also not covered the underground water sumps, septic tanks, borewells and open wells.
- 3) This certificate has been prepared based on the particulars provided by the client. If any informations in this certificate were found fault, this certificate will automatically gets cancelled.
- 4) Maintenance of the above buildings should be made periodically.
- 5) This certificate contains 7 pages and covers only the buildings mentioned therein and not any other buildings in the premises.
- 6) If the certificate is found tampered illegally, any corrections/ alterations, misuse for other puposes, without permission/ knowledge/ signature of the Panel Engineer, this certificate will automatically gets cancelled.



தருமபுரி மாவட்ட ஊடகத் தலைவரி அவர்களின் நடவடிக்கைகள்

மு.நி.வெ.வி. திரு. கா. பாலசுந்தரன் இ.ந.ப.

ந.ந.எ.க.உ. (1) 62 891/2000

நாள் 27.1.2001

பொருள்: திரையரங்குகள் - தருமபுரி மாவட்டம் பொறியாளர் பட்டியல் தருமபுரி மாவட்டம் - பொறியாளர் திரு. பி. எஸ். ரமேஷ் பாபு என்பவரிடம் பெயர் பட்டியலில் சேர்த்துக் கொடுக்க வேண்டும்.

பாரிவை: சென்னை பொதுப்பணித் துறை முதலமை பொறியாளர் (ஜெனரல்) கழகம் என்.எ.இ.டி.டி 1/ஜெ.டி/52898/2000 நாள் 11.1.2001.

.....

குறை:

தருமபுரி மாவட்டம் மற்றும் நகரில் வசிக்கும் வகுை பொறியாளர் திரு. பி. எஸ். ரமேஷ் பாபு என்பவரிடம் 1965ம் வருட தமிழ் நாடு பொதுக் கட்டடங்களின் கீழ் தருமபுரி மாவட்டம் பொறியாளர்களின் பட்டியலில் சேர்க்கை கோரி வண்ணப்பதித்தார்.

2. மேற்படி பொறியாளரின் வண்ணப்பதி தேவையான பந்த குறைகளுக்கான சென்னை பொதுப்பணித் துறை தலைமை பொறியாளர் அவர்களுக்கு அனுப்பப்பட்டது.

3. மேற்படி முகிமொழிவுகளைப் பொறியாளர் குடிவரைப் பரிசீலனை செய்யப்பட்டு மேற்படி பொறியாளர் திரு. பி. எஸ். ரமேஷ் பாபு என்பவரை கிளாஸ் 1 பிளவில் தயிபாரி பொறியாளர்களுக்கான பட்டியலில் சேர்க்கலாம் என பாரிவைவில் குறிப்பிடப்பட்ட கடிதத்தில் தெரிவிக்கப் பட்டுள்ளது.

4. பாரிவைவில் குறிப்பிடப்பட்ட கடிதத்தில் குறிப்பிடாத கடிதங்கள் திரு. பி. எஸ். ரமேஷ் பாபு என்பவரை தருமபுரி மாவட்டத்தில் 1965ம் வருட பொது கட்டடங்கள் உரிமையாளர்களின் தருமபுரி மாவட்ட பொறியாளர்கள் பட்டியல் கிளாஸ் 1 பிளவில் சேர்த்து இது காலம் குணப்படுத்தப்படும்.

/உண்மை நகல்/

ஒ.கா.பாலசுந்தரன், மாவட்ட ஊடகத் தலைவரி

தலைமை பொறியாளர் (குற்றவியல்)

பெயர்

திரு. பி. எஸ். ரமேஷ் பாபு, பி. இ. டி. எல். ஆர். அசோகியேட்டி

முதல்தளம் டி. கி. கே. காந்திபாளையம்

ஒப்புகை பெற்ற பதிவுகளை.

தபபாதி ரோடு

தருமபுரி 636701

நகல்: செயற்பொறியாளர், பொதுப்பணித் துறை கட்டடக் கோட்டம், தருமபுரி-5

* கண்காண்புடி பொறியாளர், பொதுப்பணித் துறை கட்டடக் கோட்டம் (கட்டுமானம்)



27.1.2001