

K.Dis.No : 15 / 2025
DATE : 26.04 .2025

O/o. Harur Fire and Rescue Station
HARUR-636903

NO OBJECTION CERTIFICATE

SUB : Tamil Nadu Fire and Rescue Services - Office of the Fire and Rescue Station,
Harur - Issue to no objection certificate for School Recognition -Regarding.

- Ref : 1. Government Order No : 117, School Education (Q1) Department,
Dated: 07.09.2004.
2. Government Order No: 122, School Education (2) Department,
Dated: 14.09.2004.
3. Government Order No: 123, School Education (2) Department,
Dated: 14.09.2004.
4. Application dated on 25.04. 2025 from the Correspondent of
Jayam Vidhyalaya School, Harur-636 903.

With reference to the above Government orders and an Application by JAYAM VIDHYALAYA SCHOOL, Survey No: 100/1A, 100/1B1, 99/3C1B, 99/3C2B, Nambipatti -636903, Chinnakuppam Panchayat, Pappiredipatti Taluk, Dharmapuri District, was inspected on 26.04.2025 by Thiru. K.Kamaraj , Station Officer, Fire and Rescue Station, Harur in the view of our Fire and Rescue Services Department, there is NO OBJECTION for granting Recognition to the above said school.

Conditions :


1. Fire Protection devices shall be placed in (generator room, class room Laboratory and computer room) the wall or easy to handle as per provisions of national Building code 2015 and Indian standards.
2. Water tanks should always be kept in full.
3. Mock drill should be conducted periodically.
4. Emergency exit signs should be in Red colour that even glows in the dark.
5. First Aid kit should be kept and used properly.
6. Do not accumulate waste materials in the school premises.
7. Cooking room should be separate from the school building and LPG gas cylinders should be used safely without leakage.



To:
The Correspondent,
Jayam vidhyalaya School,
Nambipatti-636903
Chinnankuppam Panchayat,
Pappirddypatti Tk.,
Dharmapuri Dt.

Copy to :

1. District officer, Dharmapuri.
2. Concern Authority one who grants License.


26/4/2025
STATION OFFICER,
Fire and Rescue Services,
Harur-636903
Dharmapuri Dt.

